



दिल्ली मेट्रो रेल कॉर्पोरेशन लि० DELHI METRO RAIL CORPORATION LTD.

(भारत सरकार एवं दिल्ली सरकार का संयुक्त उपक्रम)
(A JOINT VENTURE OF GOVERNMENT OF INDIA AND GOVT. OF DELHI)

OFFICE OF PROJECT DIRECTOR / PATNA METRO

DMRC/Patna Metro/PD-2/PC03/11/VOL-08/4724.

Date: 29.03.2023

To,
Project Manager,
Larsen and Toubro Limited,
Patna U.G. Metro-PC-03 Project Office,
2nd Floor, Muratlal Prakash Tower,
Veer Kunwar Singh Chowk, Keshri Nagar,
Nalapar, Patna-800024
Email: Aloke.dey@Intecc.com

(Kind Attention: Mr. Aloke Kumar Dey)

Sub: Contract PC-03: "Design and Construction of Twin Tunnel by Shield TBM, Tunnel by Cut& Cover, Underground Ramp at Rajendra Nagar and Six Underground Metro Stations viz. Rajendra Nagar, Moin Ul Haq Stadium, University, PMCH, Gandhi Maidan & Akashvani with Entry/Exits & Connecting subway including Architectural Finishing, Water Supply, Sanitary Installation & Drainage Works on New ISBT to Patna Station of Corridor-2 of Phase-I of Patna MRTS"- **Submission of Credentials & Test report of Swellable bar of M/s Maruti Techno Rubber Pvt. Ltd. - Reg.**

Ref: (i) LOA No. DMRC/20/III-743/2020 dated 29.12.2021.
(ii) L&T Letter-LTC-PC03/DMRC/Con/2023/1559, dated: 15.02.2023.
(iii) DMRC/Patna Metro/PD-02/PC03/011/4689 dated: 24.03.2023.

Dear Sir,


Vide letter under reference (ii) above, M/s Larsen & Toubro had submitted the Credentials & Test report of Swellable Bar of M/s Maruti Techno Rubber Pvt. Ltd. The same has been scrutinised by this office and observations were communicated vide letter under reference (iii).

Further, it is to inform that this office has No Objection for use of Swellable Bar of M/s Maruti Techno Rubber Pvt. Ltd subjected to following conditions:

1. Every lot should accompany with MTC.
2. Test should be conducted as per approved ITP prior to use.
3. Submission of observations issued vide letter under ref.(iii).
3. Performance of the Swellable Water stop may be reviewed during the work and NOC may be revoked in case of unsatisfactory performance

Thanking You,

With Regard,


Ajay Kumar
(PD/PM-2) 29.03.23

Copy to: PM-02/DMRC, PM-03/DMRC, and DGM/Quality for necessary action.